


Institute for Groundwater Studies

IGS Laboratory Services
University of the Free State
339, BLOEMFONTEIN, 9300
+27-(0)51 - 401 2317
+27-(0)51 - 444 6538 e-mail: igs@ufs.ac.za



Test Report

Page 1 of 3

Client: Kareeberg Municipality

Contact: Frans Groenewaldt

Delivered by: Marius

Date delivered: 07 February 2013

Date sampled: 07 February 2013

Case 2013-124

Determinand	Sample number:		SANS 241:2006&2011 specifications	Carnarvon Hospital		Carnarvon Kliniek	Vanwyksvlei Mun kantoor	Vosburg Mun Kantoor
	Lab number:	Units		K1	Value	K2	K3	K4
Heterotrophic plate count	cfu/ml		1000	40	752			267
Total coliforms	cfu/ml		10	0	1		1	3
E.coli	cfu/100ml		0	0	0		1	0

Bacterial note: All the parameters tested are within the specifications.

Signed:

L. Deyzel

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies

Date issued: 9 February 2013

NOV 11/2